

FRANKLIN COUNTY HEALTH DEPARTMENT

919-746-7042


PERMIT NUMBER: 131630	CONST. IMPROVE PERMIT	DATE: 09.08.99	29086	SIZE: 1A
APPLICANT: OLDE HERITAGE BUILDERS 1006 N ARENDELL AVE ZEBULON NC 27597		OWNER: STALLING CROSSING ASSOC  919 7817445		
TELEPHONE: 269-4555		DESCRIPTION: 5 YEAR <input type="checkbox"/> LIFETIME: <input type="checkbox"/>		
COMMENT: SFD		LOCATION / DIRECTIONS: STALLINGS CROSSING #33 39.76 Morbin Dr 1/2 Valerie - 2nd hand on 12		
FEE: 125.00 15742		SIGNATURE OR OWNER OR AUTHORIZED AGENT:		

THE ABOVE SIGNATURE INDICATES THAT I HAVE READ, UNDERSTAND, AND AGREE WITH ALL PROVISIONS AND INFORMATION AS OUTLINED ON THE BACK SIDE OF THIS FORM

TOPO <u>PS</u>	TEXTURE <u>PS</u>	STRUCTURE <u>PS</u>	DEPTH <u>—</u>
R. HOR <u>PS</u>	SOIL. WET <u>S</u>	AVAIL. SP <u>PS</u>	OTHER <u>—</u>
MINRL <u>SE</u>	OVERALL <u>PS</u>	LTAR <u>.35</u>	
#BEDRMS <u>3</u>	GPD <u>360</u>	DISPOSAL <u>—</u>	TYPE. SYS <u>coml</u>
SZ. TANK <u>900gal</u>	SZ. CHAMB <u>—</u>	NITRIFI <u>3x350'</u>	TYPE. WAT <u>well</u>
SITE. LOC <u>—</u>	MAX TRENCH DEP <u>30"</u>	TYP. FAC <u>—</u>	

REMARKS: Setbacks: 110'-well, 10'-prop-lines, 5'-foundation. Run lines w/ contours. Lot must be surveyed before septic system is installed.

What to move up to  
To off Road.  
Contractor called 4/24/02 septic system  
(pump out something)  
Septic Tank  
DB1000  
2/18/02  
A+A Rhodes Services  
pressure manifold  
distribution



Pump System  
✓ Lines 4/24/02  
✓ Pump  
Front setback changed  
3/11/02 JRW

IMPROVEMENT PERMIT DATE: <u>9-13-99</u>	ENV HEALTH SPEC: <u>[Signature]</u>
CONSTRUCTION AUTHORIZATION DATE: <u>9-13-99</u>	ENV HEALTH SPEC: <u>[Signature]</u>
OPERATION PERMIT DATE: <u>5/3/02</u>	ENV HEALTH SPEC: <u>[Signature]</u>