



# JOHNSTON COUNTY ENVIRONMENTAL HEALTH DEPARTMENT

309 E. Market Street  
Smithfield, North Carolina 27577  
Telephone: 919-989-5180 • Fax: 919-989-5190

430

Application # 103191 Parcel # 06G05020F

Name: South Park Dev. Address: 42 Scalet Oak Run Clayton

Location: SR 1010 2.10 miles on Right.

Facility - Type: 4br SFD (60'x60') S/D & Lot # OAKwood 9/1 Lot 3

Soil Site Classification: PS LTAR: .35

Bedrooms: 4 Design Daily Sewage Flow: 480 Lot Area: ± .59 Ac

New Construction: Yes Repair: Ma Upgrade: Na Water Supply: Public

Septic Tank Size: 1000+ w Risers Grease Trap Size: \_\_\_\_\_

Pump Tank Size: 1000 Pump(s) Size: 1/4-1/2 hp 12 gpm @ 15' TDH 8" Dia w Down

Drainfield Type: Pump to Gravel / Accepted Square Feet: 1350

# of Lines: 5 Width: 3 Length: 5-90 Depth: 18-22

Design/Layout by: MJS Improvement Permit Issued by: MJS Date: 7-31-13 Exp. Date: 7-31-18

Inspection: Lines: EB 3/27/14 OK Septic Tank: EB D-Box: EB

Pump Tank: EB Pump(s) Pressure: EB

Drainage: ALARM: EB Contractor: Carroll


### AUTHORIZATION FOR WASTEWATER SYSTEM CONSTRUCTION

ISSUED BY: M Southwick 989-5181 DATE ISSUED: July 31 2013

By rule, this septic system requires the use of an effluent filter and a waterproof seal. A riser and septic marker may also be required. Systems shall be installed as shown in sketch or according to attached plans and specifications. Any unauthorized site disturbance, filling, soil removal, or layout changes may result in the permit being revoked. Improvement permit is valid for 5 years from date of issuance unless otherwise indicated. The owner, agent accepts & verifies the conditions of the permit as indicated below.

OWNER/AGENT: \_\_\_\_\_ DATE: \_\_\_\_\_

\*TO ASSURE PROPER OPERATION MAINTENANCE IS REQUIRED\*



OPERATION PERMIT BY: [Signature] DATE: 7/2/14

218